CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 3550-0450:104 Page 1 of 1

CATEGORY: Door Closers/Holder/releasing Devices

LISTEE: LCN Closers, 121 Railroad Ave., Princeton IL 61356

Contact: *Ruth Gallianetti (815) 875-3311 Fax (815) 879-1495

DESIGN: Models SEM7820, SEM7860, SEM7870, SEM7840, SEM7850 and SEM7830. Refer to

listee's data sheet for detailed product description and operational considerations.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances

and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as door holder. The units may be used in conjunction with a separately listed

automatic fire detection device approved for releasing device service and fire alarm control

units.

*Rev. 06-09-2002



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: JUNE 9, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager